



## **CONSUMER CONFIDENCE REPORT 2018** **CITY OF ROCKWOOD**

### **Is my water safe?**

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The Rockwood Water Department and the Great Lakes Water Authority vigilantly safeguards its water supplies and once again we are proud to report that our system has never violated a maximum level or any other water quality standard.

### **Where does my water come from?**

Your source water comes from the Detroit River, situated within the Lake St. Clair, Clinton River, Detroit River, Rouge River, Ecorse River, in the U.S. and parts of the Thames River, Little River, Turkey Creek and Sydenham watersheds in Canada. The Michigan Department of Environmental Quality in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute performed a source water assessment in 2004 to determine the susceptibility of potential contamination. The susceptibility rating is on a seven-tiered scale from “very low” to “very high” based primarily on geologic sensitivity, water chemistry, and contaminant sources. The susceptibility of our Detroit River source water intakes were determined to be highly susceptible to potential contamination. However, all four Detroit water treatment plants that use source water from Detroit River have historically provided satisfactory treatment of this source water to meet drinking water standards.

GLWA has initiated source-water protection activities that include chemical containment, spill response, and a mercury reduction program. GLWA participates in a National Pollutant Discharge Elimination System permit discharge program and has an emergency response management plan. In 2015, GLWA received a grant from The Michigan Department of Environmental Quality to develop a source water protection program for the Detroit River intakes. The program includes seven elements that include the following: roles and duties of government units and water supply agencies, delineation of a source water protection area, identification of potential of source water protection area, management approaches for protection, contingency plans, siting of new sources and public participation and education.

If you would like to know more about the Source Water Assessment report or a complete copy of this report please contact the water department at (734) 379-9496

### **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline (800 426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land

or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

### **Lead Contamination in Drinking Water**

If present, elevated levels of lead can cause serious health problems, especially for pregnant woman and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Rockwood is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

### **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800 426-4791).

## **Cryptosporidium Language**

The Great Lakes Water Authority monitored for Cryptosporidium in our source water (Detroit River) from our Southwest Water Treatment Plant during 2016. Cryptosporidium was detected twice in our source water samples. A follow-up water sample was collected from the treated water and Cryptosporidium was not found to be present. Cryptosporidium is a microbial pathogen found in surface water throughout the U.S. Although filtration removes Cryptosporidium, the most commonly-used filtration methods cannot guarantee 100 percent removal. Our monitoring indicates the presence of these organisms in our source water. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of Cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immunocompromised people, infants and small children and the elderly are at greater risk of developing life threatening illness. We encourage immunocompromised individuals to consult their doctors regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water.

If you have any questions or comments contact: Robert Boron  
Director of Public Services  
32409 Fort Road  
Rockwood, MI 48173  
(734) 379-9496

## Southwest Water Treatment Plant 2018 Regulated Detected Contaminants Tables

### 2018 Inorganic Chemicals – Monitoring at the Plant Finished Water Tap

Regulated Contaminant	Test Date	Unit	Health Goal <b>MCLG</b>	Allowed Level <b>MCL</b>	Highest Level Detected	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Fluoride	6-12-2018	ppm	4	4	0.66	n/a	no	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	6-12-2018	ppm	10	10	0.41	n/a	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Barium	5-16-2017	ppm	2	2	0.01	n/a	no	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits

### 2018 Disinfection By-Products – Monitoring in Distribution System, Stage 2 Disinfection By-Products

Regulated Contaminant	Test Date	Unit	Health Goal <b>MCLG</b>	Allowed Level <b>MCL</b>	Highest LRAA	Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Trihalomethanes (TTHM)	2018	ppb	n/a	80	44	35 – 61	Yes	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	2018	ppb	n/a	60	11	7 – 14	No	By-product of drinking water disinfection

### 2018 Disinfectant Residuals – Monitoring in Distribution System by Treatment Plant

Regulated Contaminant	Test Date	Unit	Health Goal <b>MRDLG</b>	Allowed Level <b>MRDL</b>	Highest RAA	Quarterly Range of Detection	Violation yes/no	Major Sources in Drinking Water
Total Chlorine Residual	Jan-Dec 2018	ppm	4	4	0.58	0.48-0.61	No	Water additive used to control microbes

### 2018 Turbidity – Monitored every 4 hours at Plant Finished Water

Highest Single Measurement Cannot exceed 1 NTU	Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)	Violation yes/no	Major Sources in Drinking Water
0.19 NTU	100 %	No	Soil Runoff

Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

### 2017 Lead and Copper Monitoring at Customers' Tap

Regulated Contaminant	Test Date	Unit	Health Goal <b>MCLG</b>	Action Level <b>AL</b>	90 <sup>th</sup> Percentile Value*	Number of Samples over <b>AL</b>	Violation yes/no	Major Sources in Drinking Water
Lead	2017	ppb	0	15	0	0	No	Corrosion of household plumbing system; Erosion of natural deposits.
Copper	2017	ppm	1.3	1.3	0	0	No	Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives.

\*The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met.

**Southwest Water Treatment Plant  
2018 Regulated Detected Contaminants Tables**

Regulated Contaminant	Treatment Technique 2018	Typical Source of Contaminant
<b>Total Organic Carbon (ppm)</b>	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each quarter and because the level was low, there is no TOC removal requirement	Erosion of natural deposits

Radionuclides 2014							
Regulated contaminant	Test date	Unit	Health Goal MCLG	Allowed Level	Level detected	Violation Yes/no	Major Sources in Drinking water
<b>Combined Radium 226 and 228</b>	5-13-14	pCi/L	0	5	<b>0.65 + or - 0.54</b>	no	Erosion of natural deposits

Contaminant	MCLG	MCL	Level Detected 2018	Source of Contamination
<b>Sodium (ppm)</b>	n/a	n/a	<b>6.36</b>	Erosion of natural deposits

GLWA voluntarily monitors for Cryptosporidium and Giardia in our untreated source water monthly. The untreated water samples collected from our Southwest plant indicated the presence of one Giardia cyst in March. In addition, monitoring indicated the presence of one Giardia cyst and one Cryptosporidium oocyst in the untreated water from the Southwest plant in July. Additional testing was performed on the treated water at the Southwest plant and Cryptosporidium was absent. All other samples collected in the year 2018 were absent for the presence of Cryptosporidium and Giardia. Systems using surface water like GLWA must provide treatment so that 99.9 percent of Giardia lamblia is removed or inactivated.

Cryptosporidium is a microbial parasite found in surface water throughout the United States. Although Cryptosporidium can be removed by filtration, the most commonly used filtration cannot guarantee 100% removal. Current test methods do not enable us to determine if these organisms are dead or alive. Symptoms of infection include nausea, diarrhea and abdominal cramps. Most healthy persons can overcome the disease within a few weeks. However, immuno-compromised people (such as those with AIDS, undergoing chemotherapy or recent organ transplant recipients) are at a greater risk of developing a severe, life-threatening illness. Immuno-compromised persons should contact their doctor to learn about appropriate precautions to prevent infection. Cryptosporidium must be taken in through the mouth to cause disease and it may be passed by other means than drinking water.

## KEY TO THE DETECTED CONTAMINANTS TABLE

Symbol	Abbreviation	Definition/Explanation
>	Greater than	
<b>AL</b>	Action Level	The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.
<b>HAA5</b>	Haloacetic Acids	HAA5 is the total of bromoacetic, chloroacetic, dibromoacetic, dichloroacetic, and trichloroacetic acids. Compliance is based on the total.
<b>LRAA</b>	Locational Running Annual Average	
<b>MCL</b>	Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
<b>MCLG</b>	Maximum Contaminant Level Goal	The level of contaminant in drinking water below which there is no known or expected risk to health.
<b>MRDL</b>	Maximum Residual Disinfectant Level	The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
<b>MRDLG</b>	Maximum Residual Disinfectant Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.
<b>n/a</b>	not applicable	
<b>ND</b>	Not Detected	
<b>NTU</b>	Nephelometric Turbidity Units	Measures the cloudiness of water.
<b>pCi/L</b>	Picocuries Per Liter	A measure of radioactivity
<b>ppb</b>	Parts Per Billion (one in one billion)	The ppb is equivalent to micrograms per liter. A microgram = 1/1000 milligram.
<b>ppm</b>	Parts Per Million (one in one million)	The ppm is equivalent to milligrams per liter. A milligram = 1/1000 gram.
<b>RAA</b>	Running Annual Average	
<b>TT</b>	Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.
<b>TTHM</b>	Total Trihalomethanes	Total Trihalomethanes is the sum of chloroform, bromodichloromethane, dibromochloromethane and bromoform. Compliance is based on the total.
<b>µmhos</b>	Micromhos	Measure of electrical conductance of water
<b>°C</b>	Celsius	A scale of temperature in which water freezes at 0° and boils at 100° under standard conditions.

Colleen Oney  
City Clerk

Publish: Sunday, May 12, 2019

